

# Renewable NH<sub>3</sub> for grid-scale sustainable energy: *Sector coupling for economic competitiveness*

Matthew J. Palys<sup>1</sup>, Michael Reese<sup>2</sup>, Prodromos Daoutidis<sup>1</sup>

<sup>1</sup>*Chemical Engineering and Materials Science, University of Minnesota*

<sup>2</sup>*West Central Research and Outreach Center, University of Minnesota*


November 9<sup>th</sup>, 2021




# Renewable energy transition: Energy storage?

- Transition to renewables underway
  - Renewable portfolio standards: 32 states<sup>1</sup>
  - Need seasonal energy storage needed for high penetrations<sup>2-4</sup>: Renewable NH<sub>3</sub>

U.S. renewable portfolio standards by state



Energy storage technology capacity and duration



Source: EIA (2020). Database of State Incentives for Renewable Energy and Efficiency.

[1] EIA (2021). Renewable energy explained - Portfolio standards.

[2] Rouwenhurst et al. (2019). *Renew. Sust. Energ. Rev.* 114, 109339.


[3] Sánchez et al. (2021). *Appl. Energy* 293, 116956.

[4] Cesaro et al. (2021). *Appl. Energy* 282, 116009.

# Renewable $H_2$ and $NH_3$ as energy storage

Our previous work:  **$H_2$  and  $NH_3$  for small-scale 100% renewable energy storage**


- Lowest cost systems use both in combination: Efficiency vs. storage cost<sup>1</sup>
- Seasonal storage for competitive renewable CHP in remote locations<sup>2</sup>



[1] Palys et al. (2020). *Comput. Chem. Eng.* 136, 106785.

[2] Palys et al. (2021). *Optim. Contr. Appl. Meth.* DOI:10.1002/oca.2793.

# This work: Energy transition with renewable H<sub>2</sub> and NH<sub>3</sub>




**What role does renewable NH<sub>3</sub> play in energy transition?**

# Combined planning and scheduling model for energy transition

---


**Plan** installation of renewable generation and storage in each investment period



# Combined planning and scheduling model for energy transition

**Plan** installation of renewable generation and storage in each investment period

**Schedule** operation of new and previously installed renewable generation and storage



**Account for renewable intermittency without oversizing<sup>1,2</sup>**

[1] Palys et al. (2020). *Comput. Chem. Eng.* 136, 106785.

[2] Palys et al. (2021). *Optim. Contr. Appl. Meth.* DOI:10.1002/oca.2793.

# Combined planning and scheduling model for energy transition

---

**Minimize:** Net present cost

## Decisions

- Planning - Made once for each investment period
- Scheduling - Made for each operating period in each investment period

## Constraints

- Installed capacity continuity between investment periods
- Renewable energy standards
- Power generation + storage discharge > Power demand + storage charge
- Storage inventory balances
- Production rate/inventory bounds
- Production ramping bounds



*Relates planning and scheduling*

**Mixed integer linear programming (MILP) model**

# Energy transition case study: Southern California

- Planning from 2025 to 2040
  - 5-year investment periods
- 500 MW in 2025
- 160 MW, 340 MW existing wind and PV<sup>1</sup>
  - 7% and 14% energy supply
- \$35/MWh conventional generation in 2025<sup>2</sup>
- Scheduling: Wind and PV capacity factors, demand data
  - Synthesized from 10 cities
  - Open access<sup>3,4</sup>
  - Demand: 50% commercial, 50% residential



[1] U.S. EIA (2020). State electricity profiles.

[2] U.S. EIA (2021). Annual energy outlook 2021.

[3] NREL (2019). NSRDB, 1991-2005 Update: Typical Meteorological Year 3.


[4] EERE (2019). OpenEI Commercial and Residential Hourly Load Profiles for TMY3.

# Energy transition case study: Southern California

Renewable portfolio standards  
**40% in 2025**  
**4% increase per year**

Demand growth  
**1% per year<sup>1</sup>**

Fuel cost increase  
**2% per year<sup>1</sup>**




[1] U.S. EIA (2021). Annual energy outlook 2021.



[2] EU JRC. (2014). ETRI 2014: Energy technology reference indicator projections for 2010-2050.

# Southern California optimal economics

**NPC: 2,790 MM\$** (25-year project lifetime, 7.5% discount rate)




# Southern California energy systems in 2025 and 2030




- Maximum allowable conventional generation
- No storage at lower renewable penetrations
- 2030: Wind investment for night generation

# Southern California energy system in 2035




## 2035 optimal renewable generation and storage




- Considerable PV capacity increase
- H<sub>2</sub> and small NH<sub>3</sub> storage added

# Southern California energy system in 2040




## 2040 optimal renewable generation and storage




- $NH_3$  capacity increased
  - 3x production, 5x storage, 8x generation
- Battery storage included

# Southern California energy storage schedules in 2040



**Renewable  $NH_3$  for seasonal energy storage**


# Sector coupling with renewable $\text{NH}_3$



- Fertilizer to agriculture sector
- Hydrogen carrier for fuel cell vehicle sector

# Southern California sector coupling economics




NPC: 2,680 MM\$ NPC ← 110 MM\$ reduction



# Conclusions

Conceptual case study with publicly available data


- Renewable NH<sub>3</sub> for seasonal storage grid-scale energy transition
- Sector coupling accelerates renewable NH<sub>3</sub> adoption



# Conclusions

Conceptual case study with publicly available data

- Renewable NH<sub>3</sub> for seasonal storage grid-scale energy transition
- Sector coupling accelerates renewable NH<sub>3</sub> adoption



Combined investment planning-scheduling model for renewable energy transition

- Can be easily customized: Demands, technologies, policy
- **Want to analyze real scenarios!**

# Acknowledgements


---

## Xcel Energy



## ARPA-E Refuel


Grant USDOE / DE-AR0000804




## UMN Office of the Vice President for Research



## Daoutidis research group



## UMN renewable NH<sub>3</sub> project team



# Grid-scale renewable NH<sub>3</sub> for sustainable energy: *Sector coupling for economic competitiveness*

Matthew J. Palys<sup>1</sup>, Michael Reese<sup>2</sup>, Prodromos Daoutidis<sup>1</sup>

<sup>1</sup>*Chemical Engineering and Materials Science, University of Minnesota*

<sup>2</sup>*West Central Research and Outreach Center, University of Minnesota*

November 9<sup>th</sup>, 2021



# Literature review: Renewable NH<sub>3</sub> and H<sub>2</sub> as energy storage

---

## Our previous work: **Renewable H<sub>2</sub> and NH<sub>3</sub> for small-scale energy storage**

- Both in combination optimal for islanded storage systems @ 1-10 MW scale<sup>1</sup>
- NH<sub>3</sub> enables economical 100% renewable CHP in remote locations<sup>2</sup>

## Large-scale renewable NH<sub>3</sub> for energy

- Competitive by 2040 in systems with high renewable penetration<sup>3,4</sup>
  - Fuel for combustion turbines
- Best chemical storage medium for durations > 3 months at state scale<sup>5</sup>
- Best seasonal energy storage at continental scale in 2050<sup>6</sup>

[1] Palys et al. (2020). *Comput. Chem. Eng.* 136, 106785.

[2] Palys et al. (2021). *Optim. Contr. Appl. Meth.* DOI:10.1002/oca.2793.

[3] Sánchez et al. (2021). *Appl. Energy* 293, 116956.

[4] Cesaro et al. (2021). *Appl. Energy* 282, 116009.

[5] Tso et al. (2019). *Comput. Aided Chem. Eng.* 47, 1-6.

[6] Ikäheimo et al. (2018). *Int. J. Hydrogen Energy* 43(36), 17295-17308.

# Generation and storage cost and performance projections

	Capital investment (MM\$)				Operating cost - % of capital				Energy efficiency	Production/storage lower bound
	2025	2030	2035	2040	2025	2030	2035	2040		
Wind turbines (MW)	1.22	1.15	1.11	1.08	1.38	1.51	1.54	1.57	-	-
PV arrays (MW)	0.46	0.38	0.34	0.31	1.38	1.51	1.54	1.57	-	-
Electrolysis (MW)	0.7	0.53	0.46	0.42	1.50	1.50	1.50	1.50	75%	5%
Air separation (kt/y)	0.18	0.17	0.16	0.16	3.50	3.50	3.50	3.50	0.12 MWh/t	50%
NH <sub>3</sub> synthesis (kt/y)	0.38	0.36	0.34	0.32	3.50	3.50	3.50	3.50	0.48 MWh/t	50%
H <sub>2</sub> fuel cell (MW)	1	0.79	0.7	0.63	2.00	2.00	2.00	2.00	55%	5%
NH <sub>3</sub> CCGT (MW)	0.8	0.79	0.78	0.77	2.50	2.50	2.50	2.50	60%	20%
Battery power interface (MW)	0.25	0.19	0.15	0.12	1.60	2.00	2.40	2.80	-	20%
Battery storage (MWh)	0.39	0.29	0.24	0.2	1.88	2.00	2.13	0.25	90%	20%
H <sub>2</sub> Storage (t)	0.96	0.87	0.74	0.62	0	0	0	0	-	1%
N <sub>2</sub> Storage (t)	5.0E-03	5.0E-03	5.0E-03	5.0E-03	0	0	0	0	-	1%
NH <sub>3</sub> Storage (t)	7.0E-04	7.0E-04	7.0E-04	7.0E-04	0	0	0	0	-	0%

# Southern California power balance schedule in 2040

